

General safety instructions: information on restrictions related to use of the light fixtures (class, IP, etc), can be found both on the fixture label and on our website at www.rovasi.com.

The wiring schematics can be found on page 2 of the document.


ELECTRONIC EQUIPMENT:

S: On/Off.

ACCESSORIES







F3.A3
On/Off



2.7W / 250mA

220KXS.4-I1118
220KXS.4-I1119



LED technology and performance data are constantly changing. Current details should therefore be checked with ROVASI in order to ensure that its still the mostup to date reference. Updated data will be supplied on request. [12.07.2022]


Installation instructions. Mains supply wires

- Wiring type and cross section
- Solid wire a cross section of 1.5mm^2 . Strip 8,5-9,5 mm of insulation from the cables to ensure perfect operation of terminals.
- Use one wire for each terminal connector only.
- Use each strain relief channel for one cable only.
- Installation may require advice from a qualified person.
- Single lights apt for inner use outer.

Wiring guidelines

- Cable length is 190mm.
- Short circuit, overload, open circuit and thermal protection.

Wiring diagram S: On/Off



Input / Output terminal

