



Koramu XS 300

Two sides light emission IP66 bollards

INSTALLATION INSTRUCTIONS

ROVASI

Positive Lighting



Tc max=85°C Risk group(EN 62471:2008)=0

Fitting must only be used complete with their protection cover. Tempered safety glass or polycarbonate cover of dimensions 141x52,5 mm and 4 mm thickness.

Installation cable must support 110°C temperature. Feeding cable must be cable pipe 3x1 mm². Installation may require advice.



General safety instructions: information on restrictions related to use of the light fixtures (class, IP, etc), can be found both on the fixture label and on our website at www.rovasi.com.

The wiring schematics can be found on page 2 of the document.


ELECTRONIC EQUIPMENT:

S: On/Off.

ACCESSORIES







F3.A3
On/Off



3.9W / 350mA

320KXS.4-I1120
320KXS.4-I1121



LED technology and performance data are constantly changing. Current details should therefore be checked with ROVASI in order to ensure that its still the mostup to date reference. Updated data will be supplied on request. [05.09.2022]



BSI Cert ISO 9001:2015 - n°FM 39346
BSI Cert ISO 14001:2015 - n°EMS 554685

Ronda de la Font-Grossa 15
Pol. Ind. La Gavarrà
08540 Centelles | Barcelona
Spain

T. 34 93 881 35 12
T. 34 93 881 37 13

info@rovasi.com
rovasi.com

The light source contained in this luminaire shall only be replaced by the manufacturer or his service agent or a similar qualified person.


Installation instructions. Mains supply wires

- Wiring type and cross section
- Solid wire a cross section of 1.5mm^2 . Strip 8,5-9,5 mm of insulation from the cables to ensure perfect operation of terminals.
- Use one wire for each terminal connector only.
- Use each strain relief channel for one cable only.
- Installation may require advice from a qualified person.
- Single lights apt for inner use outer.

Wiring guidelines

- Cable length is 190mm.
- Short circuit, overload, open circuit and thermal protection.

Wiring diagram S: On/Off



Input / Output terminal

