

Tc max=85°C Risk group(EN 62471:2008)=0

Installation cable must support 110°C temperature. Feeding cable must be cable pipe 3x1 mm². Installation may require advice.



General safety instructions: information on restrictions related to use of the light fixtures (class, IP, etc), can be found both on the fixture label and on our website at [www.rovasi.com](http://www.rovasi.com).

The wiring schematics can be found on page 2 of the document.


### ELECTRONIC EQUIPMENT:

S: On/Off.

### ACCESSORIES







**F3.A3**  
On/Off



3.2W / 150mA

322KXS.4-I1122  
322KXS.4-I1123  
322KXS.4-I1124  
322KXS.4-I1125



LED technology and performance data are constantly changing. Current details should therefore be checked with ROVASI in order to ensure that its still the mostup to date reference. Updated data will be supplied on request. [31.03.2021]


#### Installation instructions. Mains supply wires

- Wiring type and cross section
- Solid wire a cross section of  $1.5\text{mm}^2$ . Strip 8,5-9,5 mm of insulation from the cables to ensure perfect operation of terminals.
- Use one wire for each terminal connector only.
- Use each strain relief channel for one cable only.
- Installation may require advice from a qualified person.
- Single lights apt for inner use outer.

#### Wiring guidelines

- Cable length is 190mm.
- Short circuit, overload, open circuit and thermal protection.

#### Wiring diagram S: On/Off



#### Input / Output terminal

