
CUMULUS

Pendant downlights







101CML.1.02-I865



IP54 **IK05** 850°





Pendant downlight with symmetrical light distribution to achieve an effective task or ambient lighting. Neutral cylindrical body in diameter 150mm.

Protection rating against dust and moisture: complete IP54.

White painted aluminium reflector. Sandblasted metalized aluminium reflector available as option. Powder painted aluminium body available in assorted finishes, customized RAL under request.

Intermediate tempered frosted glass.

Integral driver supplied.

Electronic options for lighting control: DALI-2.

Passive temperature management: heat dissipation flows through aluminium heat sink and the fixture

max=1024 Cd

600

800

η=100.0% ▼M ▼Ø ▼LUX

2

3 3.9 114

4 5.1

5 6.4 41

1.28 1024

256 2.6

Delivered with 1meter powder painted metal rod as standard.

Mounted to the ceiling by cylindrical ceiling rose.

Light source power: 11 W

Luminaire connected power: 12.61 W

Constant Current: 350 mA

Light source luminous flux: 2125lm Luminaire luminous flux: 1254lm

CRI: >80

Colour Temperature: 4000K

Chromaticity Tolerance: MacAdam 3

Beam Angle: 63°

LOR: 59%

Average Service Life: 50000h LED reliability: 50000h L90B10

UGR: <19 under the below indicated parameters

Room dimensions X=4H/8H Reflectance 20% | 50% | 70% Luminaire spacing = 0.55m

Photobiological safety group: 1

Cd/Klm: 819

Luminaire efficiency: 99 lm/W

This product contains a light source of energy efficiency class D

Electronic Equipment

S: On/Off (AC/DC)
D: DALI-2/switchDIM/corridorFUNCTION

B: Bluetooth-Casambi

Finishes

2: RAL9005: Jet Black, 4: RAL7016: Anthracite Grey, 7: RAL9006: White Aluminium, 1: RAL9010: Pure White

Upgradeable, Replaceable, Repairable





Note

LED technology and performance data are constantly changing. Current details should therefore be checked with ROVASI in order to ensure that it is still the most up to date reference. Updated data will be supplied on request. [Last revised on 26.04.2024]

5 years guarantee



Spain



^{*}Add the suffix -S, -D, -B after the reference to indicate your electronic equipment choice.